OUTDOOR PYROTECHNICS PERMIT REQUIREMENTS

- 1. The general conduct, operation, and safety of the fireworks display must comply with NFPA 1123.
- 2. As soon as the fireworks have been delivered to the display site, they shall not be left unattended, they shall be kept dry, and unauthorized persons shall be kept a minimum of 50 feet from the fireworks.
- 3. All material shall be as specified by letter of intent, product list, and content of site and event plan which has been approved by the Reno Fire Department.
- 4. Discharge areas shall have water type B & C fire extinguishers as approved on plan. Extinguishers shall have a current State of Nevada seal.
- 5. The pyrotechnic operator shall provide a written record of all misfire pyrotechnics to the Reno Fire Department within 12 hours of the discharge.
- 6. The operator must hold a current State Of Nevada Pyrotechnic Operator's License.
- 7. The Nevada Licensed Pyrotechnic Operator shall not leave the venue and/or discharge site until all pyrotechnic devices are rendered safe, including misfire locations after the discharge has taken place.
- 8. Pyrotechnic fallout will not be allowed over spectator area.
- 9. All brush must be cleared within 200 feet of discharge site.
- 10. All areas within the 200 foot discharge area will be watered down two hours prior to shoot.
- 11. Additional firefighting personnel will be required by the Reno Fire Department. Fees shall be paid by the licensee.
- 12. The discharge of pyrotechnics may be delayed or cancelled by the Reno Fire Department due to weather and/or safety conditions.
- 13. This permit shall be posted next to the launch site.

Additional requirements may be necessary based upon inspection and review of this event.